

TABLE 1.
ASR Cycle 1 Water Quality Results – Lake Okeechobee
Cycle Period: June 1 – 17, 1989

Date	Recharge Volume (MG)	Recovered Volume	Temperature (°C)	Storage Period (days)	Recharge Conductivity (µmhos/cm)	Recharge TDS (mg/l)	Total Coliform (/100 ml)		Fecal Coliform (/100 ml)	
							Recharge	Recovered Water	Recharge	Recovered Water
	23	34	30	1	1,250 - 1,350	850				
6/1/89							110		110	
6/5/89							80		23	
6/6/89							80		30	
6/7/89								21		8
6/8/89								6		4
6/9/89								ND		ND
6/10/89								ND		ND
6/11/89								ND		ND
6/12/89								ND		ND
6/13/89								ND		ND
6/14/89								ND		ND
6/15/89								ND		ND
6/17/89								7		7

/100 ml colonies per 100 milliliters
µmhos/cm micromhos per centimeter
MG million gallons
ND Presence indicated at <2 /100 ml, which is below detection limit of 2 /100 ml.
TDS total dissolved solids