

**TABLE 3.**

ASR Cycle 3 Water Quality Results – Lake Okeechobee  
 Cycle Period: July 9, 1989 – August 21, 1989

Date	Recharge Volume (MG)	Recovered Volume	Temperature (°C)	Storage Period (days)	Recharge Conductivity (µmhos/cm)	Recharge TDS (mg/l)	Total Coliform (/100 ml)		Fecal Coliform (/100 ml)	
							Recharge	Recovered Water	Recharge	Recovered Water
	25	33	26 - 30	28	1,150 – 1,350	691 - 758				
7/10/89							70		23	
8/12/89								30		ND
8/13/89								17		ND
8/14/89								27		ND
8/15/89								7		ND
8/15/89								ND		ND
8/16/89								ND*		ND*

\* different analytical approach with a lower detection limit  
 /100 ml colonies per 100 milliliters  
 µmhos/cm micromhos per centimeter  
 MG million gallons  
 ND Presence indicated at <2 /100 ml, which is below detection limit of 2 /100 ml.  
 TDS total dissolved solids