

TABLE 4.
ASR Cycle 4 Water Quality Results – Lake Okeechobee
Cycle Period: September 6 – November 4, 1989

Date	Recharge Volume (MG)	Recovered Volume	Temperature (°C)	Storage Period (days)	Recharge Conductivity (µmhos/cm)	Recharge TDS (mg/l)	Total Coliform (/100 ml)		Fecal Coliform (/100 ml)	
							Recharge	Recovered Water	Recharge	Recovered Water
	91	144	27 - 30	0	345 - 478	268 - 336				
9/6/89							130		80	
9/13/89							23		8	
9/17/89							30		8	
9/25/89								36		14
9/26/89								2		ND
10/5/89								ND		ND
10/5/89								ND*		ND*
11/4/89								30		ND

* different analytical approach with a lower detection limit
 /100 ml colonies per 100 milliliters
 µmhos/cm micromhos per centimeter
 MG million gallons
 ND Presence indicated at <2 /100 ml, which is below detection limit of 2 /100 ml.
 TDS total dissolved solids